# **WS-TPCS Clamp on temperature transmitter**

4-20mA or 0-10VDC output



#### **Features**

- Wide choice of temperature ranges
- Output 4-20mA or 0-10VDC

## Description

Designed to measure temperature conditions on the surface of liquid flow lines. The sensor element is enclosed in a brass contact stud which is clamped to the surface of the pipe work in a position to measure the controlled condition.

For chilled water applications the sensor element and terminal board is epoxy sealed to prevent the influence of condensation in low temperature conditions.

In addition to 4-20mA and 0-10VDC output models the sensor is also available with a range of temperature measurement elements e.g. Pt100. Contact AIC for details.

For best results use a heat conducting contact paste.

This transducer is ideal for direct connection to a PLC or can be used with AIC's extensive range of DC analog input instrumentation.

Visit AIC's website (http://www.aicpl.com.au) for information about Amalgamated Instrument Co (AIC) instrumentation products.

### **Specifications**

Enclosure: Flame retardant polycarbonate

Contact stud: Brass

Band: Plated steel adjustable 15 to

125mm dia.

Supply: 2-wire loop powered or

24VAC/DC supply for 0-10VDC

output

Output: 4-20mA or 0-10VDC Body dimensions: 60mm x 60mm x 36mm

Protection: IP65

Terminals: 2.5mm<sup>2</sup> max wire

#### **Order Codes:**

WS-TPCS/40 - output 4-20mA range -10 to 40°C WS-TRCS/110 - output 4-20mA range -10 to 110°C WS-TRCS/160 - output 4-20mA range -10 to 160°C WS-TPCS/40R - output 4-20mA range -10 to 40°C, (epoxy sealed chilled water model)

WS-TPVCS/40 - output 0-10VDC range -10 to 40°C WS-TPVCS/110 - output 0-10VDC range -10 to 110°C WS-TPVCS/160 - output 0-10VDC range -10 to 160°C WS-TPVCS/40R - output 0-10VDC range -10 to 40°C,

(epoxy sealed chilled water model)

WSTPCS-1.0-0

ACN: 001 589 439

Unit 5, 28 Leighton Place Hornsby NSW 2077 Australia Telephone: +61 2 9476 2244 Facsimile: +61 2 9476 2902

e-mail: sales@aicpl.com.au Internet: www.aicpl.com.au